

Office of The Chief Medical Officer, Ghaziabad


Ref.No: DSO/IDSP/2022/ 700

Dated 04-11-2022

Safe Drinking Water, Health & Hygiene Certificate

It is certified that a combined inspection team headed by Mr. Sujit Kumar Rai from IDSP UNIT, Ghaziabad and Nagar Nigam, Ghaziabad inspected the premises J K G INTERNATIONAL SCHOOL SHAKTI KHAND II INDIRAPURAM GHAZIABAD on 3-11-2022 and found J K G INTERNATIONAL SCHOOL SHAKTI KHAND II INDIRAPURAM GHAZIABAD has safe Drinking water facilities for the person is maintaining hygienic sanitation conditions in the water as per the norms. This certificate is issued with the condition that the water quality will be maintained in future otherwise, it will automatically stand canceled on proof.

Based on Ref: DSO/IDSP/2022/ 700


(Dr. R K Gupta)

District Public Health Expert

District Surveillance Officer

District Public Health Expert

District Ghaziabad

To

J K G INTERNATIONAL SCHOOL
SHAKTI KHAND II INDIRAPURAM
GHAZIABAD

Office of The Chief Medical Officer, Ghaziabad

Ref.No. DSO/IDSP/2022/ 700

Dated 04/11/2022

PORTABLE WATER TEST REPORT

ADDRESS:- J K G INTERNATIONAL SCHOOL SHAKTI KHAND II INDIRAPURAM
GHAZIABAD.

No of sample collected : 01

Date of sample collected : 31-11-2022

Sample collection area

Sample collection area	Sample ID	Result
J K G INTERNATIONAL SCHOOL SHAKTI KHAND II INDIRAPURAM GHAZIABAD.	673	Satisfactory

Test Result

H₂S Water test kit : Negative (-Ve) after 24-48 hrs incubation


Comments:-


H₂S water test kit report - ve reflects that water is free from Coliforms Organism.

Recommendation:

Given water sample safe for drinking purpose.


Lab Technician
IDSP Lab
Ghaziabad


(Dr. Suruchi Saini)
Microbiologist IDSP Lab
Ghaziabad


(Dr R.K Gupta)
District Public Health Expert
District Surveillance Officer
District Public Health Expert
District Ghaziabad